

AENOR Product Certificate

Electric distribution cables



075/000118

AENOR, Spanish Association for Standardization and Certification, certifies that the organization

PRYSMIAN CABLES Y SISTEMAS, S.A.

with head office in: CR C-15, KM 2. PI. MASIA D'EN NOTARI
08800 VILANOVA i LA GELTRU (Barcelona - España)

supplies: Medium Voltage Power Distribution electric cable, HEPR insulated and PO sheathed. Non flame propagating and low emission of smoke and gasses acid and corrosive.

in compliance with: UNE-HD 620-9E:2010 (HD 620S2:2010)

Designation: HEPRZ1 (S)
Trade Mark: EPROTENAX PRYSMIAN
Rated Voltage U_0/U (Um): 12/20 (24) kV; 18/30 (36) kV
Restriction: 1 x 50 mm²; 1 x 95 mm²; 1 x 150 mm²; 1 x 240 mm²; 1 x 400 mm²
Type: 9E-4
Longitudinal obturation: No obturation

Production site: PI MASIA D'EN NOTARI, CR C-15, KM 2.
08800 VILANOVA i LA GELTRU (Barcelona - España)

Certification scheme: In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 75.02

Issued on: 2011-12-01
Validity date: 2017-12-01

AENOR Asociación Española de Normalización y Certificación

Chief Executive Officer

AENOR

Asociación Española de Normalización y Certificación

Genova, 6. 28004 Madrid. España
Tel. 902 102 201 - www.aenor.es