

AENOR Product Certificate

Electric distribution cables



075/000034

AENOR, Spanish Association for Standardization and Certification, certifies that the organization

PRYSMIAN CABLES Y SISTEMAS, S.A.

- with head office in: CR C-15, KM 2. PI. MASIA D'EN NOTARI
08800 VILANOVA i LA GELTRU (Barcelona - España)
- supplies: Medium Voltage Power Distribution electric cable, XLPE insulated and PO
sheathed. Without special fire propagation characteristics.
- in compliance with: UNE-HD 620-10E:2010 (HD 620S2:2010)
- References: Specified in Annex to the Certificate
- Production site: PI MASIA D'EN NOTARI, CR C-15, KM 2.
08800 VILANOVA i LA GELTRU (Barcelona - España)
- Certification scheme: In order to grant this Certificate, AENOR has tested the product and has
verified the quality system implemented for its manufacture. AENOR
performs these tasks periodically while the Certificate has not been
cancelled, in accordance with Specific Rules RP 75.02

This certificate supersedes 075/000034, dated 2009-03-17

Issued on: 2006-10-31
Modified on: 2012-01-20
Validity date: 2017-01-20



Avelino BRITO
Chief Executive Officer

Asociación Española de
Normalización y Certificación

AENOR Product Certificate

Electric distribution cables



075/000034

Annex to Certificate

Designation	Trade Mark	Rated Voltage U ₀ /U (Um)	Restriction	Type	Longitudinal obturation
RHZ1-0L	VOLTALENE PRYSMIAN ó DRAKA	6/10 (12) kV; 8,7/15 (17,5) kV; 12/20 (24) kV; 18/30 (36) kV	1 x 50 mm ² ; 1 x 95 mm ² ; 1 x 150 mm ² ; 1 x 240 mm ² ; 1 x 400 mm ² .	5E-1	Screen (0L)
RHZ1-20L	VOLTALENE PRYSMIAN ó DRAKA	6/10 (12) kV; 8,7/15 (17,5) kV; 12/20 (24) kV; 18/30 (36) kV	1 x 50 mm ² ; 1 x 95 mm ² ; 1 x 150 mm ² ; 1 x 240 mm ² ; 1 x 400 mm ² .	5E-1	Screen and conductor (20L)

Issued on: 2006-10-31
 Modified on: 2012-01-20
 Validity date: 2017-01-20


AENOR Asociación Española de Normalización y Certificación
 Avelino BRITO
 Chief Executive Officer