

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electric Power Cable

with type designation(s)
TEOF 0,6/1 kV,
TEOF Mud 0,6/1 kV

Issued to
PRYSMIAN CABLES SPAIN, S.A.
Vilanova i la Geltrú, Barcelona, Spain

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

General power and lighting. Fire resistant.
Products approved by this certificate are accepted for installation on all vessels classed by DNV GL.

Type	Rated voltage (kV)	Temp. class (°C)
TEOF 0,6/1 kV	0,6/1	90
TEOF Mud 0,6/1 kV	0,6/1	90

Issued at **Høvik** on **2020-12-18**

for **DNV GL**

This Certificate is valid until **2023-06-30**.
 DNV GL local station: **Area NB/CMC Iberia**

Approval Engineer: **Ivar Bull**

.....
Marta Alonso Pontes
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Job Id: **262.1-015325-15**
Certificate No: **TAE00002ZE**
Revision No: **1**

Product description

Type: TEOF 0,6/1 kV, TEOF Mud 0,6/1 kV

Construction:

Conductors: Tinned annealed, stranded copper Class 2 or Class 5

Core insulation: Mica tape + EPR

Inner covering: Halogen free compound

Metal covering: Copper wire braid (O) or

Galvanized steel wire braid (C) for multicore cables only

Outer sheath: SHF2 or SHF Mud

No of cores:	Cross sectional area [mm ²]
1	1,5 - 300
2, 4	1,5 - 120
3	1,5 - 185
2 / E	2,5-35 / 2,5-16
3 / E	1,5-240 / 1,5-120
4 / E	120-240 / 70-120
5	4 - 120
5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 30, 37	1,5 2,5

Application/Limitation

This type of cable is fire resistant in accordance with IEC 60331-21 (1999) and IEC 60331-1 (2018).

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Data sheets: TEOF BFOU (P5) 0,6/1 kV & TEOF BFOU (P5/P12) 0,6/1 kV, TEOF BFOU 0,6/1 kV & TEOF BFCU Mud 0,6/1 kV rev. 00 dated 05/11.

Test reports.

Tests carried out

Standard	Release	General description	Limitation
DNVGL-CP-0399	2016-03	Class Programme Electric cables	
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	

Job Id: **262.1-015325-15**
 Certificate No: **TAE00002ZE**
 Revision No: **1**

Standard	Release	General description	Limitation
IEC 60331-21	1999-04	Tests for electric cables under fire conditions – Circuit integrity – Part 21: Procedures and requirements – Cables of rated voltage up to 0,6/1,0 kV	90 min. test
IEC 60331-1	2018-03	Tests for electric cables under fire conditions - Circuit integrity - Part 1: Test method for fire with shock at a temperature of at least 830 °C for cables of rated voltage up to and including 0,6/1,0 kV and with an overall diameter exceeding 20 mm	Minimum 120 min+15 min cooling down time
IEC 60332-1-2	2006-07	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	
IEC 60332-3-22	2018-07	Tests on electric cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%
NEK 606 Ed. 4	2009-05	Cables for offshore installations. Halogen-free and/or mud resistant. Technical specification.	
CSA C22.2 No. 03	2009	4.12 Flexibility at any specified temperature	Cold bend: -40C.
CSA C22.2 No. 03	2009	4.12 Flexibility at any specified temperature	Cold impact: -35C.

Marking of product

PRYSMIAN SAP - TEOF 0,6/1 kV or TEOF Mud 0,6/1 kV – IEC 60331-21/1 – IEC 60332-3-22 - Lot No.

Job Id: **262.1-015325-15**
Certificate No: **TAE00002ZE**
Revision No: **1**

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE